

# Energy performance certificate (EPC)

35 Reay Nadin Drive SUTTON COLDFIELD B73 6UR	Energy rating <b>B</b>	Valid until: <b>19 September 2032</b>  Certificate number: <b>1054-4705-9064-1670-0887</b>
--	---------------------------	--

Property type

Non-residential Institutions: Primary Health Care Building

Total floor area


109 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy efficiency rating for this property

This property’s current energy rating is B.



Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

10 | A

If typical of the existing stock

38 | B

Properties are given a rating from A+ (most efficient) to G (least efficient).

## Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	17.34
Primary energy use (kWh/m2 per year)	182

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/3020-8206-2480-2071-6060\)](#).

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Benjamin Burnett
Telephone	
Email	<a href="mailto:ben@nrg-uk.co.uk">ben@nrg-uk.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Sterling Accreditation Ltd
Assessor ID	STER000954
Telephone	0161 727 4303
Email	<a href="mailto:info@sterlingaccreditation.com">info@sterlingaccreditation.com</a>

### Assessment details

Employer	NRG Assessments Ltd
Employer address	Hill House, Hillwood Road, Four Oaks, Birmingham, B75 5QN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	16 September 2022
Date of certificate	20 September 2022

---