



Building Energy Rating (BER)

ADVISORY REPORT

Energy use in our homes is responsible for more than a quarter of Ireland's total CO₂ emissions. Reducing energy use will save you money and is good for the environment. This report provides advice on improving your Building Energy Rating, reducing your energy usage and costs, while improving the comfort and condition of your home.

Report Date: 28/07/2009

Assessor: Seamus Dolan

Address: INNER RING MANAGEMENT LTD
STUDENT VILLAGE RIVERWALK
APT 18 BLOCK NO9 RING RD
WATERFORD CITY

BER: 100925627

MPRN: 10021217749

Ventilation

General Operational Advice.

Care should always be taken to ensure a sufficient level of ventilation to maintain fresh air levels in each room. For health and safety reasons it is important to ensure an adequate air supply to combustion appliances e.g. gas fires. If draught stripping is damaged at any time make sure to replace it.

Chimneys.

This dwelling has no chimneys.

Fan & Vents

This dwelling has one or more fans/vents.

Fans and vents increase heat loss in a dwelling by allowing heated air to escape but can be important in ensuring adequate ventilation. If there is no cover on the inside of the vents, installing controllable vent covers will allow you to control the air flow through the vents, and so can help reduce heat loss. All changes to ventilation must comply with relevant Building Regulations requirements, particularly Part F (Ventilation) and Part J (Heat Producing Appliances).

Cost: Low **Impact:** Low

Draught Lobby

This dwelling has a draught lobby.

Suspended wooden floor

This dwelling has a solid floor.

Draught Stripping

This dwelling has 100% draught stripping.

Ventilation System

This dwelling has natural ventilation.

Building Elements

Floors

General Operational Advice.

Floors can be a source of significant heat loss and dampness in a dwelling. Installing insulation will reduce this heat loss, and so reduce the energy demand of the dwelling. Floors with a heat loss greater than the current building standards (with a U-Value > 0.25) could be improved. It should be noted that installing floor insulation generally involves a considerable amount of work. The floor space must also have adequate ventilation to prevent dampness. All changes to ventilation must comply with relevant Building Regulations requirements, particularly Part F (Ventilation) and Part J (Heat Producing Appliances).

Roofs

Proper insulation will help retain valuable heat and improve overall comfort levels. If insulation is disturbed or damaged at any time, e.g. in attic space, make sure to restore or replace it.

Roof Insulation

The roof is one of the largest heat loss areas in a dwelling. Installing insulation will reduce this heat loss, and so reduce the energy demand of the dwelling. Roofs with a heat loss greater than the current building standards could be improved. The current building standard for pitched roofs that are insulated on the rafter, or for a room in roof, is to have a U-Value ≤ 0.2 . For pitched roofs that are insulated on the ceiling, the current building standard is to have a U-Value ≤ 0.16 . For flat roofs, the current building standard is to have a U-Value ≤ 0.22 . Blanket insulation, rigid board insulation or expanding foam may be used to achieve the required insulation level. Loose beads may also be used for roofs insulated on the ceiling. It should be noted that installing roof insulation generally involves a considerable amount of work. The attic/roof space must also have adequate ventilation to prevent dampness. All changes to roof insulation must comply with relevant Building Regulations requirements, particularly Part F (Ventilation), Part J (Heat Producing Appliances) and Part B (Fire Safety).

Walls

As often the largest surface area, the wall can make up one of the largest heat loss areas in a dwelling. Installing insulation will reduce this heat loss and can help reduce thermal bridging and so reduce the energy demand of the dwelling. Walls with a heat loss greater than the current building standards (i.e. have a U-Value > 0.27) could be improved. Insulation may be installed as cavity fill, where the gap between the inner and outer layers of external walls is filled with an insulating material. If cavity insulation is not applicable or is not technically possible, insulation may be installed internally or externally. Internal insulation involves a layer of insulation being fixed to the inside

surface of external walls, and a suitable fire resistant finish being incorporated or applied. External solid wall insulation is the application of an insulant and a weather-protective finish to the outside of the wall. It should be noted that installing wall insulation generally involves a considerable amount of work.

There are wall areas in this dwelling with a U-Value of <0.6 and >0.27 .

Cost: High **Impact:** Low

Windows

Much heat can be lost from dwellings through their windows as they have relatively poor thermal insulation compared to other elements of the building. Installing energy efficient windows such as low-E double glazing helps to retain heat and improves comfort through elimination of cold window surfaces and associated draughts and condensation. The use of shutters, lined curtains and blinds can improve heat retention at night and further reduce draughts. Windows with a heat loss greater than the current building standards (i.e. have a U-Value > 2) could be improved. However, it should be noted that best benefits are achieved through the upgrade from single to low E double or triple glazing. Note that single glazing can also be improved by adding secondary glazing rather than changing to proprietary double glazing.

There are window areas in this dwelling with a U-Value of <4 and ≥ 2.7 .

Cost: High **Impact:** Medium

Doors

Heat is lost from dwellings through doors which often have relatively poor thermal insulation compared to other elements of the building. Installing insulated doors will reduce this heat loss, and also generally reduce draughts through air gaps at the frames. Doors with a heat loss greater than the current building standards (i.e. have a U-Value >2.0) could be improved.

There are door(s) in this dwelling with a U-Value of <4 and ≥ 2.7 .

Cost: Medium **Impact:** Low

Hot Water

General Operational Advice.

Ensure that the hot water cylinder insulation is not disturbed or damaged. Incomplete insulation increases heat loss and costs money.

A cylinder thermostat is not required for the hot water system in this dwelling.

Hot water cylinder insulation

The hot water cylinder has factory fitted insulation.

Cylinder Timer /Thermostat

The hot water cylinder in this dwelling does not have timer and thermostat.

A hot water cylinder thermostat enables the boiler to switch off when the water in the cylinder reaches the required temperature. This minimises the amount of energy that is used and lowers fuel bills. Consider installing a hot water cylinder timer and

thermostat to reduce unnecessary heat loss from the hot water cylinder. The lower the storage temperature the less the heat loss from your cylinder. However, you should not set the storage temperature below 60°C so as to avoid the risk of legionnaires disease.

Cost: Medium **Impact:** Low

Lighting

General Operational Advice.

CFLs use 20% of the energy used by typical incandescent bulbs to give the same amount of light. A 22 Watt CFL has the same light output as a 100 Watt incandescent. LED lights use less than 10% of the energy required for corresponding tungsten lights. Low energy lighting will give highest savings in rooms that are most often used.

Lighting - low energy bulbs

There is 100% low energy lighting in this dwelling.

Space Heating

General Operational Advice.

Your automatic timer switch or programmer allows you to schedule the heating duty on the hot water system and to turn the system on and off as required. Use this facility to limit the running time for the hot water system to fit your specific needs and you will save money. Likewise the heating system can be set to provide space heating only when needed. Room thermostats normally turn the boiler and heating circulation pump off when the room temperature has reached the desired level. A room thermostat is normally located in a living area or circulations area (hall or landing). Guide temperature settings are 20°C for a living room and 16 - 18°C for circulation areas. However, the most appropriate setting depends on location of the thermostat and the heating system design. Choose the lowest setting that gives acceptable comfort conditions. Finding the setting to suit you may take some experimentation. A reduction of 1°C on your thermostat can reduce annual space heating costs by 10% or more. TRVs (Thermostatic Radiator Valves) can be set to suit the heating requirements of the room(s) in question.

Dist. System losses and gains (control category)

There are good heating system controls in this dwelling.

Main Heating System

General Operational Advice.

You should have your boiler professionally serviced at least once per year. A clean and serviced appliance will operate more economically and will have a longer service life.

Efficiency of main heating system (Electricity)

If you are using electric storage heaters, please note that they are more cost effective if you are using electricity supplied at a cheaper night-time rate. Checking your tariff with your electricity supplier could save you money.

This dwelling has an electric main heating system.

Traditional electricity production is energy intensive and use of direct electric heat sources can have a very negative impact on your BER result. A number of alternatives should be considered. Heat pumps use electricity to extract "free" heat from the ground, air or water. These natural sources of heat are naturally replenished by the sun, wind and rain. The role of the heat pump is to 'pump up' heat from a low temperature source, for example the ground under a lawn, and release it at a higher temperature into the central heating system. The type of heat pump you choose will depend on the space available inside and outside your home. For example, some heat pumps require a large buffer storage tank to be installed in your dwelling, while ground source heat pumps require either a bore hole or a large area of ground to lay the collector pipe. Heat pumps operate more efficiently when providing space heat via an underfloor heating system rather than radiators. A condensing gas or oil boiler is capable of much higher efficiencies than other types of boiler, meaning it will burn less fuel to heat this dwelling. This improvement is most appropriate if there is an existing central heating boiler which needs repair or replacement, but there may be exceptional circumstances making this impractical. Condensing boilers need a drain for the condensate which can limit where they are located. This can be borne in mind if you are considering remodelling the room containing the existing boiler even if the existing boiler is to be retained for the time being. Modern biomass boilers offer the warmth and comfort of wood heating while being highly efficient, clean burning and totally automatic, saving you time and money. They can provide a direct replacement for a regular boiler if there is an existing central heating system. Biomass boilers are often lit automatically and can continue to operate without manual intervention. Automatic fuel supply and thermostatic control means you can enjoy the comfort of biomass heating at the switch of a button. Modern biomass boilers are often self cleaning and don't require daily maintenance. Biomass boilers generate considerably less net Carbon Dioxide than gas, oil or non wood burning solid fuel boilers. If you are using electric storage heaters, please note that they are more cost effective if you are using electricity supplied at a cheaper night-time rate. Checking your tariff with your electricity supplier could save you money.

Cost: High **Impact:** High

Thermal Solar Panels

This dwelling has no solar water heating.

Solar Panels, also known as "collectors", can be fitted to a building's roof. They use the sun's heat to warm water, or another fluid, which passes through the panel. The fluid is then fed to a heat store (e.g. a hot water tank) and helps provide hot water directly or can provide a source of hot water for the central heating system in the dwelling. Solar panels work throughout daylight hours, even if the sky is overcast and there is no direct sunshine. Solar panels can also be used to meet some space heating demand. Ideally the panels should be located on an unshaded, south facing roof at a tilt angle of 30°- 45° to the horizontal. Space will be needed to accommodate an appropriately sized cylinder for the system and a thermal mixing (anti-scald) valve should also be installed.

Cost: High **Impact:** Medium

PV Solar System or Microturbine

This dwelling has no microturbine or Photo Voltaics (PV).

A solar photovoltaic (PV) system is one which converts light directly into electricity via panels placed on the roof with no waste and no emissions. This electricity is used throughout the home to supplement the electricity purchased from an energy supplier. Ideally the panels should be located on an unshaded, south facing roof at a tilt angle of 30°- 45° to the horizontal. Batteries can be used to store electricity from the PV array or wind turbine. However, this increases the installation and equipment cost as well as maintenance cost. A Micro-windturbine is a small turbine placed on the property which uses wind to generate electricity. The electricity is used throughout the home to supplement the electricity from an energy supplier. The turbine should not be subject to wind shelter. To be effective, the turbine should be at a height well clear of nearby roofs and other obstructions.

Cost: High **Impact:** High

General Energy Advice

Appliances

New kitchen appliances carry energy rating labels which rate energy efficiency on a scale of A to G. When buying new appliances look for at least A rated products which are more energy efficient and cost less to run. Do not under or overload appliances such as dishwashers and washing machines. For washing machines, a 40°C rather than a 60°C wash cycle cuts electricity use by approximately a third. (Modern washing powders and detergents can work equally effectively at lower temperatures). Defrost your freezer regularly to save energy and extend the operating life. Equipment on standby uses up to 20% of the energy it would use when fully on. When an appliance is not in use, turn it off fully.

Carbon dioxide Emissions

Using one unit of electricity in your house releases up to three times as much CO₂ as one unit of gas. The use of renewable technologies (such as solar water heating) avoids the harmful greenhouse gas emissions associated with energy production.

Lighting

Avail of natural daylight whenever possible and avoid leaving electric lights switched on in unoccupied rooms. All lighting lamps carry an energy label similar to that on appliances (i.e. an A to G label) so always choose the most efficient to suit your particular needs.

Further advice on improving the energy efficiency of your home is available from Sustainable Energy Ireland www.sei.ie

Glasnevin, Dublin 9, Ireland | T. +353-1-8369080 | info@sei.ie
Glas Naíon, Baile Átha Cliath 9, Éireann | F. +353-1-8372848 | www.sei.ie



Funded by the Irish Government under the National Development Plan 2007-2013 with programmes part-financed by the European Union