

# Energy performance certificate (EPC)

39 Stanfield Street Cwm EBBW VALE NP23 7TQ	Energy rating <b>G</b>	Valid until: <b>13 May 2035</b>
		Certificate number: <b>6435-7325-6500-0356-0206</b>

Property type	Mid-terrace house
Total floor area	63 square metres

## Rules on letting this property

### ! You may not be able to let this property

This property has an energy rating of G. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. You could make changes to [improve this property's energy rating](#).

## Energy rating and score

This property's energy rating is G. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	<b>A</b>		92 <b>A</b>
81-91	<b>B</b>		
69-80	<b>C</b>		
55-68	<b>D</b>		
39-54	<b>E</b>		
21-38	<b>F</b>		
1-20	<b>G</b>	14 <b>G</b>	

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D

- the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, no insulation	Very poor
Roof	Pitched, no insulation (assumed)	Very poor
Window	Partial double glazing	Poor
Main heating	No system present: electric heaters assumed	Very poor
Main heating control	None	Very poor
Hot water	No system present: electric immersion assumed	Very poor
Lighting	Low energy lighting in 13% of fixed outlets	Poor
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 735 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [About primary energy use](#)

### Additional information

Additional information about this property:

- Cavity fill is recommended
- Stone walls present, not insulated

## How this affects your energy bills

An average household would need to spend **£3,653 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £2,809 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 11,312 kWh per year for heating
- 3,264 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is F. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

## Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	7.8 tonnes of CO2
This property's potential production	2.0 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

## Step 1: Increase loft insulation to 270 mm

Typical installation cost	£100 - £350
Typical yearly saving	£719
Potential rating after completing step 1	<b>25 F</b>

## Step 2: Flat roof or sloping ceiling insulation

Typical installation cost	£850 - £1,500
Typical yearly saving	£109
Potential rating after completing steps 1 and 2	<b>27 F</b>

## Step 3: Cavity wall insulation

Typical installation cost	£500 - £1,500
Typical yearly saving	£76
Potential rating after completing steps 1 to 3	<b>28 F</b>

## Step 4: Internal or external wall insulation

Typical installation cost	£4,000 - £14,000
Typical yearly saving	£578
Potential rating after completing steps 1 to 4	<b>41 E</b>

## Step 5: Floor insulation (solid floor)

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£91
Potential rating after completing steps 1 to 5	<b>43 E</b>

## Step 6: Low energy lighting

Typical installation cost	£35
Typical yearly saving	£35

Potential rating after completing steps 1 to 6

44 E

## Step 7: High heat retention storage heaters

Typical installation cost

£1,600 - £2,400

Typical yearly saving

£1,016

Potential rating after completing steps 1 to 7

75 C

## Step 8: Solar water heating

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£93

Potential rating after completing steps 1 to 8

77 C

## Step 9: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost

£3,300 - £6,500

Typical yearly saving

£92

Potential rating after completing steps 1 to 9

79 C

## Step 10: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£3,500 - £5,500

Typical yearly saving

£462

Potential rating after completing steps 1 to 10

92 A

## Advice on making energy saving improvements

[Get detailed recommendations and cost estimates](#)

[Speak to an advisor from Nest](#)

## Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: [Nest](#)
- Insulation: [Great British Insulation Scheme](#)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme](#)
- Help from your energy supplier: [Energy Company Obligation](#)

## Who to contact about this certificate

## Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Heidi Wangemann
Telephone	07525152144
Email	<a href="mailto:hwenergy@outlook.com">hwenergy@outlook.com</a>

## Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024207
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

## About this assessment

Assessor's declaration	No related party
Date of assessment	6 May 2025
Date of certificate	14 May 2025
Type of assessment	► <a href="#">RdSAP</a>

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5) [Service performance \(/service-performance\)](#)

### OGI

All content is available under the [Open Government Licence v3.0](#)

(<https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/>), except where otherwise stated



ht (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-frameworkor>