
# THE GOSPEL CENTRE CASTLE STREET EYE IP23 7AW Energy rating Certificate number: 6409-1137-1092-4228-9806 Non-residential Institutions: Community/Day Centre Total floor area 135 square metres

# Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built	9 A
If typical of the existing stock	35 B

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	46.49
Primary energy use (kWh/m2 per year)	478

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the  $\underline{\text{recommendation}}$   $\underline{\text{report (/energy-certificate/0286-0209-1497-1429-1840)}}$ .

## Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mike Simpson
Telephone	(0)7770 580 902
Email	mike@epcmarketing.co.uk

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID201186	
Telephone	01225 667 570	
Email	info@quidos.co.uk	
About this assessment		
Employer	EPC Marketing Ltd	

Employer	EPC Marketing Ltd
Employer address	36B Bredfield St., Woodbridge, IP12 4NH
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	24 August 2023
Date of certificate	24 August 2023