
Energy performance certificate (EPC)				
8 Damley Road GRAVESEND DA11 0RU	Energy rating	Valid until:	21 February 2033	
DATLORU	D	Certificate number:	4904-1785-2733-1363-2297	
Property type	C	Offices and Workshop	o Businesses	
Total floor area	107 square metres			

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

9 A

38 B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	19.19
Primary energy use (kWh/m2 per year)	196

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0226-8969-0372-3215-9725)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	MOHAMMED SADDIQUE

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO003628
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	superfast epc 07595959778	
Employer address	80 GURNEY CLOSE BARKING IG11 8JY	
Assessor's declaration	The assessor is not related to the owner of the property.	
Date of assessment	22 February 2023	
Date of certificate	22 February 2023	