

Energy performance certificate (EPC)

1, New Row Fimber DRIFFIELD YO25 9LX	Energy rating G	Valid until: 18 May 2030
		Certificate number: 8040-7425-6660-7908-0296

Property type	End-terrace house
Total floor area	107 square metres

Rules on letting this property

! You may not be able to let this property

This property has an energy rating of G. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. You could make changes to [improve this property's energy rating](#).

Energy rating and score

This property's energy rating is G. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		95 A
81-91	B		
69-80	C		
55-68	D		
39-54	E		
21-38	F		
1-20	G	1 G	

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, no insulation (assumed)	Very poor
Roof	Flat, no insulation (assumed)	Very poor
Window	Mostly double glazing	Average
Main heating	No system present: electric heaters assumed	Very poor
Main heating control	None	Very poor
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Low energy lighting in 25% of fixed outlets	Average
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 783 kilowatt hours per square metre (kWh/m²).

How this affects your energy bills

An average household would need to spend **£4,974 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £3,700 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2020** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 24,221 kWh per year for heating
- 2,260 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is G. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 14.0 tonnes of CO₂

This property's potential production 3.7 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Flat roof or sloping ceiling insulation	£850 - £1,500	£1,019
2. Internal or external wall insulation	£4,000 - £14,000	£1,068
3. Floor insulation (solid floor)	£4,000 - £6,000	£253
4. Add additional 80 mm jacket to hot water cylinder	£15 - £30	£25
5. Low energy lighting	£45	£31
6. High heat retention storage heaters	£2,000 - £3,000	£1,234
7. Solar water heating	£4,000 - £6,000	£71
8. Solar photovoltaic panels	£3,500 - £5,500	£350
9. Wind turbine	£15,000 - £25,000	£702

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Eric Ash
Telephone	01482396278
Email	jane.mears@eastriding.gov.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/022463
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	18 May 2020
Date of certificate	19 May 2020
Type of assessment	RdSAP